

VERNON PUBLIC SCHOOLS – BID#VPS-FY14-005 – QUESTIONS & ANSWERS

PUBLIC ADDRESS SYSTEM AND INTERCOM SYSTEM FOR VERNON CENTER MIDDLE SCHOOL

Clarifications from the Site Survey on May 27, 2014:

- 1) Existing classroom phones are to remain and be connected to newly proposed system.
- 2) Newly proposed system must have E911 capability-without having to dial other than 911.
- 3) Provide unit pricing for phone replacement- if damaged.
- 4) Existing system shall be completely checked out for classroom integrity (speaker and phone) and any issues shall be identified before the awarded contractor proceeds with new installation. Failure to report any items that are not functioning will be the awarded contractor's responsibility to repair at no added cost.
- 5) Include cost for 46 additional speakers as marked on attached floor layout by green dot.
- 6) Include price to replace existing speaker if found to be not functional.
- 7) Include price to replace/add amplifier if needed.

###